

GERAUSCHDATEN X350

Luftmenge m ³ /h	Druck Pa	Strahlung Gerät (1) Schallpegel dB(A)	Abluft (1) Schallpegel dB(A)	Zuluft (1) Anschluss oben Schallpegel dB(A)	Zuluft (1) Anschluss unten Schallpegel dB(A)
150	25	43,5	37,5	49,5	46,5
150	50	46,0	40,5	51,0	52,0
200	50	44,0	43,0	54,0	55,0
200	100	49,5	46,0	59,0	57,5
245	50	46,5	46,0	57,5	58,0
250	100	50,5	47,5	61,5	62,0
300	100	51,0	49,0	63,0	62,5
300	150	54,5	50,5	64,5	64,0
350	100	53,0	51,5	65,0	64,5
350	150	57,0	53,0	67,5	65,5

(1) Labormessungen nach ISO 3741

