

## GERAUSCHDATEN X500

Luftmenge m <sup>3</sup> /h	Druck Pa	Strahlung Gerät (1) Schallpegel dB(A)	Abluft (1/2) Schallpegel dB(A)	Zuluft (1/2) Schallpegel dB(A)
200	25	41,5	40,5	57,0
250	50	46,5	46,0	62,5
300	100	50,5	49,0	65,5
350	50	50,5	50,0	67,5
450	100	55,5	55,5	72,0
450	150	57,0	55,5	74,0
500	100	58,5	56,5	74,0
500	150	59,0	57,5	76,5

(1) Labormessungen nach ISO 3741

